



April 9, 2018

City of Allegan
 C/O Doug Sweeris
 Allegan, MI, 49010
dsweeris@cityofallegan.com

RE: Residential Well Water Sampling Results

Dear Doug:

Attached is the laboratory report from a sample we recently collected from your potable well. The sample was analyzed by ALS in Kelso, Washington; Pace in Minneapolis, Minnesota for a limited number of perfluoroalkyl and polyfluoroalkyl substances (PFAS) including perfluorooctane sulfonate (PFOS) and perfluorooctanoic acid (PFOA).

The samples were un-treated groundwater collected from an aerator-free raw water tap for each well. The laboratory report is summarized below. For reference, the table includes the MDEQ PFOS/PFOA Part 201 Generic Residential and Non-Residential Cleanup Criteria for drinking water of 70 parts per trillion (ppt). Other PFAS substances do not currently have MDEQ Criteria.

| Summary of Laboratory Results | | | | |
|-------------------------------|--------------------|--------------------------------|---|------------------------|
| Sample | PFOS/PFOA Detected | Total PFOS/PFOA Detected (ppt) | Total PFOS/PFOA Detected Above or Below MDEQ Criteria (70 ppt, or ng/l) | Non-PFOS/PFOA detected |
| PW #1 | No | None | Below | None |
| PW #2 | No | None | Below | None |
| PW #5 | No | None | Below | None |

Thank you for using the services of F&V. If you need additional information, please contact me.

Sincerely,
 FLEIS & VANDENBRINK

Brian L. Rice, P.E.
 Manager, Environmental Services Group

att: Laboratory Report and Chain of Custody
 cc: Mark Worrall, MDEQ
 Karen Vorce, MDEQ

2960 Lucerne Drive SE, Suite 100
Grand Rapids, MI 49546
 P: 616.977.1000
 F: 616.977.1005
www.fveng.com